



Vent connections are provided on the SAF tank turrets, to allow connection to the site's venting system. The design of the venting system will vary from site to site and is the responsibility of the installation contractor.

| 1 | 15/03/10 | RP | RU | RP | ISSUED FOR INFO | | | | | | | | | |
|-----------------------|----------|---|-------|--|-----------------|--|--|---|--|--|--|--------------|------------------------------|---------------|
| REV. | DATE | BY | CHKD. | APPD. | DESCRIPTION | | | | | | | | | |
| S | W | N | | | | GENERAL TOLERANCES (unless noted otherwise) GRP FABRICATED ± 5mm ± 0.5° MACHINED ± 2mm ± 0.2° ± 0.5mm ± 0.1° | | IMPORTANT INVERT LEVEL NOTE (RIBBED TANKS ONLY!): The inlet and outlet Invert Level(IL) shown on this drawing is to internals of the shell unless otherwise stated. For Invert level to the outside of the shell ribs, see the conversion below: Ø1.0m, 1.2m, 1.5m, 1.8m, 2.5m IL+50mm ('X') Ø3.0m, 4.0m IL+75mm ('X') | | TITLE CSAF30 SCHEME SHOWING TYPICAL KIOSK CONNECTIONS | | | | |
| FOR INTERNAL USE ONLY | | 1ST ANGLE PROJECTION | | | | DRAWN BY RP DATE 15/03/10 | | CHKD. RU DATE 15/03/10 | | APPD. RP DATE 15/03/10 | | SCALE NTS | DRAWING No. CSAF30 LAYOUT | REVISION 1 |
| A3 | | DO NOT SCALE IF IN DOUBT ASK ALL DIMENSIONS IN MM | | THIS DRAWING IS THE PROPERTY OF PREMIER TECH AQUA Ltd. AND IS NOT TO BE COPIED IN PART OR WHOLE WITHOUT WRITTEN PERMISSION | | TANKS SUPPLIED WITH LOOSE SHAFTS DO NOT COME SUPPLIED WITH A FIXING KIT. THIS IS THE RESPONSIBILITY OF THE SITE CONTRACTOR. | | | | | | | | |