


| 1  | 15/03/10 | RP                   | RU  | RP   | ISSUED FOR INFO |
|--|----------|----------------------|---|--|-----------------|
| REV.   | DATE     | BY                   | CHKD.   | APPD.  | DESCRIPTION     |
| S  | W        | N                    |   | E  |                 |
| FOR INTERNAL USE ONLY  |          | 1ST ANGLE PROJECTION |   | <b>GENERAL TOLERANCES (unless noted otherwise)</b><br>GRP ± 5mm ± 0.5°<br>FABRICATED ± 2mm ± 0.2°<br>MACHINED ± 0.5mm ± 0.1° |                 |
| <b>DO NOT SCALE IF IN DOUBT ASK ALL DIMENSIONS IN MM</b>   |          |                      | <b>THIS DRAWING IS THE PROPERTY OF PREMIER TECH AQUA Ltd. AND IS NOT TO BE COPIED IN PART OR WHOLE WITHOUT WRITTEN PERMISSION</b> |  |                 |
| <b>IMPORTANT INVERT LEVEL NOTE (RIBBED TANKS ONLY):</b><br>The inlet and outlet Invert Level(IL) shown on this drawing is to internals of the shell unless otherwise stated.<br>For Invert level to the outside of the shell ribs, see the conversion below:<br>1.0m, 1.2m, 1.5m, 1.8m, 2.5m IL+50mm ('X')<br>3.0m, 4.0m IL+75mm ('X') |          |                      |   |  |                 |
| <b>TANKS SUPPLIED WITH LOOSE SHAFTS DO NOT COME SUPPLIED WITH A FIXING KIT. THIS IS THE RESPONSIBILITY OF THE SITE CONTRACTOR.</b>   |          |                      |   |  |                 |



**TITLE** CSAF40 SCHEME SHOWING TYPICAL KIOSK CONNECTIONS

|                  |                  |                  |              |                              |               |
|------------------|------------------|------------------|--------------|------------------------------|---------------|
| DRAWN BY<br>RP   | CHKD.<br>RU      | APPD.<br>RP      | SCALE<br>NTS | DRAWING No.<br>CSAF40 LAYOUT | REVISION<br>1 |
| DATE<br>15/03/10 | DATE<br>15/03/10 | DATE<br>15/03/10 |              |                              |               |