



2	12.11.18	CW	KB	PS	INLET/OUTLET PIPEWORK REMOVED
1	10/10/14	RP	KB	RP	ISSUED FOR INFORMATION
REV.	DATE	BY	CHKD.	APPD.	DESCRIPTION
				GENERAL TOLERANCES (unless noted otherwise) GRP ± 5mm FABRICATED ± 2mm MACHINED ± 0.5mm ANGLE ± 0.5° ± 0.2° ± 0.1°	
FOR INTERNAL USE ONLY A3		DO NOT SCALE IF IN DOUBT ASK ALL DIMENSIONS IN MM		THIS DRAWING IS THE PROPERTY OF PREMIER TECH AQUA Ltd. AND IS NOT TO BE COPIED IN PART OR WHOLE WITHOUT WRITTEN PERMISSION	

IMPORTANT INVERT LEVEL NOTE (RIBBED TANKS ONLY!):
 The inlet and outlet Invert Level(IL) shown on this drawing is to internals of the shell unless otherwise stated.
 For Invert level to the outside of the shell ribs, see the conversion below:
 ø1.0m, 1.2m, 1.5m, 1.8m, 2.5m IL+50mm ('X')
 ø3.0m, 4.0m IL+75mm ('X')

TANKS SUPPLIED WITH LOOSE SHAFTS DO NOT COME SUPPLIED WITH A FIXING KIT.
 THIS IS THE RESPONSIBILITY OF THE SITE CONTRACTOR.

TITLE Sales drawing for
 Millenium 3000L Septic Tank

DRAWN BY RP	CHKD. KB	APPD. RP	SCALE NTS	DRAWING No. Millenium 3m3	REVISION 1
DATE 10/10/14	DATE 10/10/14	DATE 10/10/14			